



CONTRACTOR REQUEST FOR INFORMATION NO. 1

Date: May 15, 2019
Project Name: Avondale Schools
2017 Technology Bond
Large Format Video Systems
RFP No. 1182
Auburn Hills, Michigan

IDS Project No.: 17254-1000 BP-10

The Contractor requests that Integrated Design Solutions, LLC supply to them the following information/clarification relating to the above project.

1. The Extron cabling is shielded CAT. So, it would be advisable to proffer a **Mandatory Alternate** to replace this existing cable.

<u>Greg Koss</u> Name	<u>Advanced Lighting & Sound</u> Company	<u>May 14, 2019</u> Date
--------------------------	---	-----------------------------

IDS Response:

1. Extron recommends but does not require shielded Category cabling. Refer to page 2 of the Bid Form. A mandatory alternate to replace the existing cable is required as part of your bid submission. As specified, bidders are expected to follow applicable codes, standards and manufacturer recommendations when bidding and installing the specified systems.

<u>Scott Smith</u> Name	<u>Senior Associate</u> Title	<u>May 15, 2019</u> Date
----------------------------	----------------------------------	-----------------------------

cc: File

F:\2017\17254\1000\Corr\Design\BP10 - Large Format Video\rfi001.docx

5211 cascade road se, ste. 300
grand rapids, mi 49546

1441 w. long lake road, ste. 200
troy, mi 48098

248-823-2100 www.ids-troy.com

INTEGRATED **design** SOLUTIONS
architecture engineering interiors & technology